



Certificate of Compliance

This certificate is issued for the following:

Pipe Hanger Components for Automatic Sprinkler Systems

<i>Product Designation</i>	<i>Hanger Rod Size, mm</i>	<i>Component Description</i>	<i>For Nominal Pipe Sizes, in.</i>
BZ Plus 10*	M10	Wedge Anchor	3/4 through 4
BZ Plus 12*	M12	Wedge Anchor	5, 6, 8
BZ Plus 16*	M16	Wedge Anchor	10, 12

*These expansion shields are available in zinc plated carbon steel and 316 stainless steel.

Prepared for:

MKT- Metall- Kunststoff- Technik GmbH & Co KG
Auf Dem Immel 2
D-067685 Weilerbach
Germany

FM Approvals Class: 1952

Approval Identification: 0003002567

Approval Granted: June 21, 1999

To verify the product continues to be Approved please refer to www.approvalguide.com.

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA

January 3, 2018

Date



Member of the FM Global Group